




Side View



Front View



Top Plan



Section A-A

Note:

- 1- The size of the Tap should be $\frac{1}{2}$ ".
- 2- The Tap should be connected with Tank.
- 3- Stand should be a little wider in base.
- 4- The thickness of metal sheet should be gage 18".
- 5- The material of stand should be 1.5mm profile materials.
- 6- Stirrup sized 1.5", 3mm thick.
- 7- All joints should welded well.
- 8- Not acceptable any china production.

ORCD KABUL, AFGHANISTAN	SURVEYED BY ORCD AFG	CHECKED BY	ENG FARID ULLAH	SCALE	1:1	PROVINCE	Helmand & Nimrose	PROJECT NAME	Hand Washing Facilities	SHEET NO.
WatSTP	DESIGNED BY	REVIEWED BY	ENG FARID ULLAH	DATE	2022	DISTRICT	Different Districts	DRAWING TITLE		
Engineering Section (ES)	DRAWN BY	APPROVED BY	ORCD AFG	DRAWING NO.	01	VILLAGE	Different Villages	Single Hand Washing Facility		